

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 3550-1615:164 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

DESIGN: Models D370B, D370C, D371B, D371C, D372B, D372C door closer/holders. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24V AC/DC, 110VAC

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances. The unit is intended to be mounted in a horizontal position only.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as door closer/holders for use with separately listed compatible detectors and fire alarm control units.

FORMERLY: 3550-0801:196

XL: **3550-1039:100**

01-04-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division